

**Water Quality Parameter Monitoring Form  
Oregon Health Authority  
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.5				Y
3	7.5				Y
4	7.5				Y
5	7.6				Y
6	7.6				Y
7	7.7				Y
8	7.5				Y
9	7.7				Y
10	7.7				Y
11	7.6				Y
12	7.7				Y
13	7.4				Y
14	7.6				Y
15	7.5				Y
16	7.4				Y
17	7.5				Y
18	7.4				Y
19	7.5				Y
20	7.5				Y
21	7.4				Y
22	7.6				Y
23	7.5				Y
24	7.6				Y
25	7.4				Y
26	7.4				Y
27	7.3				Y
28	7.5				Y
29	7.3				Y
30	7.5				Y
31	7.5				Y
<b>Total N's</b> (No = N = Excursion)					<b>0</b>

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41-00473

System Name: Lebanon

Entry Point: WTP-B

Sample Period: Oct-21  
Month/Year

**Number of excursions during this month** 0  
(Count the number of days when any WQP was less than the minimum required)

**Number of excursions during this month** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

Minimum Water Quality Parameter(s) as set by State:		MIN	MAX	
pH		<b>7.0</b>	<b>9.0</b>	
Alk				(Alkalinity)
PO4				(Orthpphosphate)
Other				( )

Print Name: Chris Germond

Signature: Chris Germond

Date: 11/3/21

Sent to DWP within 10 days after end of sampling period.