

**Water Quality Parameter Monitoring Form  
Oregon Health Authority  
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.8				Y
2	7.8				Y
3	7.7				Y
4	7.7				Y
5	Plant Offline				Y
6	7.8				Y
7	7.8				Y
8	7.7				Y
9	7.8				Y
10	7.7				Y
11	7.8				Y
12	Plant Offline				Y
13	7.6				Y
14	7.6				Y
15	7.6				Y
16	7.8				Y
17	7.8				Y
18	7.7				Y
19	7.8				Y
20	7.6				Y
21	7.7				Y
22	7.6				Y
23	7.6				Y
24	7.5				Y
25	7.6				Y
26	Plant Offline				Y
27	7.6				Y
28	7.6				Y
29	7.6				Y
30	7.6				Y
31	7.6				Y
<b>Total N's</b> (No = N = Excursion)					<b>0</b>

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41-00473

System Name: Lebanon

Entry Point: WTP-B

Sample Period: \_\_\_\_\_ Dec-21  
Month/Year

**Number of excursions during this month** 0  
(Count the number of days when any WQP was less than the minimum required)

**Number of excursions during this month** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

Minimum Water Quality Parameter(s) as set by State:		
	MIN	MAX
pH	<b>7.0</b>	<b>9.0</b>
Alk		(Alkalinity)
PO4		(Orthpphosphate)
Other		(_____)

Print Name: Chris Germond

Signature: Chris Germond

Date: 1/5/22

Sent to DWP within 10 days after end of sampling period.

**Water Quality Parameter Monitoring Form**  
**Oregon Health Authority**  
**Lead & Copper Rule Corrosion Control**

Notes:

12/22/2022	Finished pH probe reading incorrectly. Reinstalled software and working again. Lowest pH of the day while a finish
	water pump was running was 7.62 pH.