

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	Plant Offline				Y
2	7.6				Y
3	7.6				Y
4	7.6				Y
5	7.6				Y
6	7.5				Y
7	7.6				Y
8	Plant Offline				Y
9	7.5				Y
10	7.7				Y
11	7.7				Y
12	7.7				Y
13	7.5				Y
14	7.5				Y
15	Plant Offline				Y
16	7.4				Y
17	7.6				Y
18	7.6				Y
19	7.5				Y
20	7.4				Y
21	7.4				Y
22	Plant Offline				Y
23	7.3				Y
24	7.4				Y
25	7.5				Y
26	7.5				Y
27	7.4				Y
28	7.4				Y
29	7.5				Y
30	7.5				Y
31	7.5				Y
Total N's (No = N = Excursion)					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41-00473

System Name: Lebanon

Entry Point: WTP-B

Sample Period: Jan-23
Month/Year

Number of excursions during this month 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter(s) as set by State:		
	MIN	MAX
pH	<u>7.0</u>	<u>9.0</u>
Alk		
PO4		
Other		

(Alkalinity)
(Orthpphosphate)
()

Print Name: Chris Germond

Signature: Chris Germond

Date: 2/2/23

Sent to DWP within 10 days after end of sampling period.