

**Water Quality Parameter Monitoring Form  
Oregon Health Authority  
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.6				Y
3	7.5				Y
4	Plant offline				Y
5	7.6				Y
6	7.6				Y
7	Plant offline				Y
8	7.6				Y
9	7.6				Y
10	7.5				Y
11	Plant offline				Y
12	7.5				Y
13	7.5				Y
14	7.8				Y
15	7.6				Y
16	7.7				Y
17	7.4				Y
18	7.5				Y
19	7.3				Y
20	7.3				Y
21	7.4				Y
22	7.5				Y
23	7.6				Y
24	7.4				Y
25	7.4				Y
26	7.6				Y
27	7.4				Y
28	7.4				Y
29	7.6				Y
30	7.4				Y
31	7.6				Y
<b>Total N's</b> (No = N = Excursion)					<b>0</b>

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41-00473

System Name: Lebanon

Entry Point: WTP-B

Sample Period: May-23  
Month/Year

**Number of excursions during this month** 0  
(Count the number of days when any WQP was less than the minimum required)

**Number of excursions during this month** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

Minimum Water Quality Parameter(s) as set by State:		
	MIN	MAX
pH	<u>7.0</u>	<u>9.0</u>
Alk		(Alkalinity)
PO4		(Orthpphosphate)
Other		(_____)

Print Name: Chris Germond

Signature: Chris Germond

Date: 6/7/23

Sent to DWP within 10 days after end of sampling period.