

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.7				Y
3	7.6				Y
4	7.7				Y
5	7.7				Y
6	7.4				Y
7	7.5				Y
8	7.5				Y
9	7.6				Y
10	7.7				Y
11	7.7				Y
12	7.8				Y
13	7.9				Y
14	7.8				Y
15	7.7				Y
16	7.6				Y
17	7.6				Y
18	7.8				Y
19	7.8				Y
20	7.8				Y
21	7.6				Y
22	7.5				Y
23	7.5				Y
24	7.4				Y
25	7.8				Y
26	7.9				Y
27	7.8				Y
28	7.8				Y
29	7.7				Y
30	7.8				Y
31	#N/A				
Total N's (No = N = Excursion)					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41-00473

System Name: Lebanon

Entry Point: WTP-B

Sample Period: Nov-23
Month/Year

Number of excursions during this month 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameter(s) as set by State:**

	MIN	MAX	
pH	7.0	9.0	
Alk			(Alkalinity)
PO4			(Orthpphosphate)
Other			(_____)

Print Name: Tyson Keene

Signature: 

Date: 12-5-23

Sent to DWP within 10 days after end of sampling period.