

**Water Quality Parameter Monitoring Form  
Oregon Health Authority  
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.8				Y
2	7.9				Y
3	7.9				Y
4	7.9				Y
5	7.9				Y
6	7.8				Y
7	8.0				Y
8	7.8				Y
9	7.9				Y
10	7.9				Y
11	7.9				Y
12	7.9				Y
13	7.8				Y
14	7.9				Y
15	7.9				Y
16	7.8				Y
17	7.9				Y
18	7.9				Y
19	7.9				Y
20	7.8				Y
21	7.9				Y
22	7.9				Y
23	7.8				Y
24	7.9				Y
25	7.9				Y
26	7.9				Y
27	7.8				Y
28	7.7				Y
29	7.8				Y
30	7.6				Y
31	#N/A				
<b>Total N's</b> (No = N = Excursion)					<b>0</b>

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41-00473

System Name: Lebanon

Entry Point: WTP-B

Sample Period: Jun-24  
Month/Year

Number of excursions during this month 0  
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

Minimum Water Quality Parameter(s) as set by State:		
	MIN	MAX
pH	7.0	9.0
Alk		
PO4		
Other		

(Alkalinity)  
(Orthpphosphate)  
(\_\_\_\_\_)

Print Name: Tyson Keene

Signature: 

Date: 7-5  
Sent to DWP within 10 days after end of sampling period.