

Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control

Day	PH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.8				Y
3	7.6				Y
4	7.6				Y
5	7.6				Y
6	7.6				Y
7	7.6				Y
8	7.9				Y
9	8.0				Y
10	7.6				Y
11	7.7				Y
12	7.8				Y
13	7.7				Y
14	7.7				Y
15	7.7				Y
16	8.1				Y
17	7.7				Y
18	7.9				Y
19	8.0				Y
20	7.7				Y
21	7.6				Y
22	7.6				Y
23	7.9				Y
24	7.5				Y
25	7.4				Y
26	7.5				Y
27	7.6				Y
28	7.6				Y
29	7.5				Y
30	7.8				Y
31	7.4				Y
Total N's (No = N = Excursion)					0

<<Have
 minimums been
 met for this day?

ENTRY POINT

PWS ID: 41-00473

System Name: Lebanon

Entry Point: WTP-B

Sample Period: May-25
 Month/Year

Number of excursions during this month 0

(Count the number of days when any WQP was less
 than the minimum required)

Number of excursions during this month 0

(Over 9 excursions in 6 months is a violation. Entry Point
 and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality

Parameter(s) as set by State:

	MIN	MAX	
pH	7.0	9.0	
Alk			(Alkalinity)
PO4			(Orthpphosphate)
Other			()

Print Name: Tyson Keene

Signature: 

Date: 6-5-25

Sent to DWP within 10 days after end of sampling period.