

Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control

Day	PH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.6				Y
3	7.6				Y
4	7.6				Y
5	7.7				Y
6	7.7				Y
7	7.7				Y
8	7.7				Y
9	7.6				Y
10	7.6				Y
11	7.5				Y
12	7.8				Y
13	7.6				Y
14	7.7				Y
15	7.7				Y
16	7.6				Y
17	7.6				Y
18	7.6				Y
19	7.7				Y
20	7.6				Y
21	7.7				Y
22	7.7				Y
23	7.6				Y
24	7.6				Y
25	7.7				Y
26	7.8				Y
27	7.8				Y
28	7.7				Y
29	7.6				Y
30	7.6				Y
Total N's (No = N = Excursion)					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41-00473

System Name: Lebanon

Entry Point: WTP-B

Sample Period: Sep-25
Month/Year

Number of excursions during this month 0
 (Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameter(s) as set by State:**

	MIN	MAX
pH	7.0	9.0
Alk		
PO4		
Other		

(Alkalinity)
 (Orthpphosphate)
 ()

Print Name: Tyson Keene

Signature: [Signature]

Date: 10-2-25

Sent to DWP within 10 days after end of sampling period.

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone: (971)-673-0471 Website: www.dhs.state.or.us/publichealth/dwp/index.cfm