

Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control

Day	PH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6				Y
3	7.7				Y
4	7.6				Y
5	7.6				Y
6	7.6				Y
7	7.6				Y
8	7.6				Y
9	7.6				Y
10	7.7				Y
11	7.7				Y
12	Plant Off				Y
13	7.6				Y
14	7.6				Y
15	7.6				Y
16	7.5				Y
17	7.6				Y
18	7.6				Y
19	Plant Off				Y
20	7.6				Y
21	7.6				Y
22	7.6				Y
23	7.5				Y
24	7.5				Y
25	7.6				Y
26	Plant Off				Y
27	7.6				Y
28	7.6				Y
29	7.6				Y
30	7.7				Y
31	7.9				Y
Total N's (No = N = Excursion)					0

<<Have minimums been met for this day? **ENTRY POINT**
PWS ID: 41-00473
System Name: Lebanon
Entry Point: WTP-B
Sample Period: Oct-25
Month/Year

Number of excursions during this month 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter(s) as set by State:		
	MIN	MAX
pH	7.0	9.0
Alk		
PO4		
Other		

Print Name: Tyson Keene

Signature: 

Date: 11-5-25

Sent to DWP within 10 days after end of sampling period.

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (971)-673-0471 Website: www.dhs.state.or.us/publichealth/dwp/index.cfm