

**Water Quality Parameter Monitoring Form  
Oregon Health Authority  
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.8				Y
2	7.7				Y
3	7.7				Y
4	Plant Off				Y
5	7.8				Y
6	7.7				Y
7	7.6				Y
8	7.6				Y
9	7.6				Y
10	7.7				Y
11	Plant Off				Y
12	7.6				Y
13	7.6				Y
14	7.6				Y
15	7.5				Y
16	7.5				Y
17	7.7				Y
18	Plant Off				Y
19	7.7				Y
20	7.6				Y
21	7.6				Y
22	Plant Off				Y
23	7.6				Y
24	7.7				Y
25	Plant Off				N
26	7.6				Y
27	7.6				Y
28	7.6				Y
29	Plant Off				Y
30	7.7				Y
31	7.6				Y
<b>Total N's</b> (No = N = Excursion)					<b>0</b>

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41-00473

System Name: Lebanon

Entry Point: WTP-B

Sample Period: Jan-26  
Month/Year

**Number of excursions during this month** 0  
(Count the number of days when any WQP was less than the minimum required)

**Number of excursions during this month** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

Minimum Water Quality Parameter(s) as set by State:		
	MIN	MAX
pH	<b>7.0</b>	<b>9.0</b>
Alk		
PO4		
Other		

(Alkalinity)  
(Orthpphosphate)  
( )

Print Name: Tyson Keene

Signature: 

Date: 2-5-26  
Sent to DWP within 10 days after end of sampling period.