

**Water Quality Parameter Monitoring Form  
Oregon Health Authority  
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	Plant	Off			Y
2	7.6				Y
3	7.7				Y
4	7.6				Y
5	Plant	Off			Y
6	8.0				Y
7	7.8				Y
8	Plant	Off			Y
9	7.8				Y
10	7.7				Y
11	Plant	Off			Y
12	7.7				Y
13	7.9				Y
14	7.8				Y
15	Plant	Off			Y
16	7.8				Y
17	7.8				Y
18	Plant	Off			Y
19	7.8				Y
20	7.9				Y
21	7.7				Y
22	Plant	Off			Y
23	7.7				Y
24	7.7				Y
25	Plant	Off			Y
26	7.7				Y
27	8.1				Y
28	7.8				Y
29	Plant	Off			Y
30	7.8				Y
31	7.9				Y
<b>Total N's</b> (No = N = Excursion)					<b>0</b>

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41-00473

System Name: Lebanon

Entry Point: WTP-B

Sample Period: Mar-26  
Month/Year

**Number of excursions during this month** 0  
(Count the number of days when any WQP was less than the minimum required)

**Number of excursions during this month** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

Minimum Water Quality Parameter(s) as set by State:		
	MIN	MAX
pH	7.0	9.0
Alk		
PO4		
Other		

(Alkalinity)  
(Orthpphosphate)  
( )

Print Name: Tyson Keene

Signature: 

Date: 4-1-26  
Sent to DWP within 10 days after end of sampling period.