



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID # DATE	Sample Location	pH	Alk	PO4	Sili	Y/N
4/4	Pump House Sample Tap	7.4				Y
4/7	 	7.4				Y
4/11		7.4				Y
4/14		7.3				Y
4/18		7.3				Y
4/21		7.4				Y
4/25		7.3				Y
4/28		7.3				Y

County: Linn Agency: C

DISTRIBUTION

PWS ID 4100474

LAWRENCE SUBDIVISION

WTR.ASSN.

Sample Period = April / 2022
Month/Year

Sample Frequency: Every 12 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

(N = No = Excursion) Total N's 0

Print Name: Jody Anthony

Signature: [Handwritten Signature] Date: 5/9/2022