

Date

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

1D # Sample Location Y/N <Has sample pH Alk PO4 County: Linn Agency: C met the Pumphouse Sampleton 7.4 DISTRIBUTION minimum(s)? PWS ID 4100474 7.4 Y LAWRENCE SUBDIVISION 7.3 WTR.ASSN. 5/20 7.3 5/23 Sample Period = May / 2022 Month/Year 7.3 5/26 7.3 Sample Frequency: 5/3/ Every 12 months 7.3 Distribution Samples required: Number of excursions during this Sample Period = ____ (Number of locations when any WQP was less than the minimum.) Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period. Reference -Minimum Water Quality Parameters as set by State: pH 7.2 (N = No = Excursion)Total N's Print Name: _ Jody Signature: _ Date: 6/3/22 Send to Drinking Water Program within 10 days after end of sampling period DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone: (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp