

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				Y
2	7.3				Y
3	7.3				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.3				Y
8	7.3				Y
9	7.2				Y
10	7.2				Y
11	7.3				Y
12	7.3				Y
13	7.3				Y
14	7.3				Y
15	7.3				Y
16	7.3				Y
17	7.3				Y
18	7.3				Y
19	7.3				Y
20	7.3				Y
21	7.4				Y
22	7.4				Y
23	7.4				Y
24	7.4				Y
25	7.4				Y
26	7.4				Y
27	7.4				Y
28	7.4				Y
29	7.3				Y
30	7.3				Y
31					

<<Have
minimums
been met for
this day?

County: Linn

Agency: LINN COUNTY

ENTRY POINT

EP-A

PWS ID 4100474

LAWRENCE SUBDIVISION WTR ASSN

Sample period: June / 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Jody Anthony
Signature: Jody Anthony
Date & Phone#: 7-9-25 (541) 992-9835

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0