

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				Y
2	7.3				Y
3	7.3				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.4				Y
8	7.4				Y
9	7.5				Y
10	7.5				Y
11	7.6				Y
12	7.6				Y
13	7.6				Y
14	7.6				Y
15	7.6				Y
16	7.6				Y
17	7.6				Y
18	7.7				Y
19	7.7				Y
20	7.7				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.5				Y
25	7.5				Y
26	7.5				Y
27	7.5				Y
28	7.5				Y
29	7.5				Y
30	7.5				Y
31					

(No = N = Excursion) **Total N's** ☒

<<Have
minimums
been met for
this day?

County: Linn

Agency: LINN COUNTY

ENTRY POINT

EP-A

PWS ID 4100474

LAWRENCE SUBDIVISION WTR ASSN

Sample period: September / 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH

Print Name: Jody Anthony

Signature: Jody Anthony

Date & Phone#: 10/6/25 (541) 980-9835

Send to DWP within 10 days after end of
sampling period