

| Day | pH  | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1   | 7.6 |     |      |       | Y   |
| 2   | 7.6 |     |      |       | Y   |
| 3   | 7.6 |     |      |       | Y   |
| 4   | 7.6 |     |      |       | Y   |
| 5   | 7.6 |     |      |       | Y   |
| 6   | 7.6 |     |      |       | Y   |
| 7   | 7.6 |     |      |       | Y   |
| 8   | 7.7 |     |      |       | Y   |
| 9   | 7.7 |     |      |       | Y   |
| 10  | 7.7 |     |      |       | Y   |
| 11  | 7.6 |     |      |       | Y   |
| 12  | 7.6 |     |      |       | Y   |
| 13  | 7.6 |     |      |       | Y   |
| 14  | 7.6 |     |      |       | Y   |
| 15  | 7.6 |     |      |       | Y   |
| 16  | 7.7 |     |      |       | Y   |
| 17  | 7.7 |     |      |       | Y   |
| 18  | 7.7 |     |      |       | Y   |
| 19  | 7.7 |     |      |       | Y   |
| 20  | 7.7 |     |      |       | Y   |
| 21  | 7.7 |     |      |       | Y   |
| 22  | 7.7 |     |      |       | Y   |
| 23  | 7.7 |     |      |       | Y   |
| 24  | 7.7 |     |      |       | Y   |
| 25  | 7.7 |     |      |       | Y   |
| 26  | 7.7 |     |      |       | Y   |
| 27  | 7.7 |     |      |       | Y   |
| 28  | 7.7 |     |      |       | Y   |
| 29  |     |     |      |       |     |
| 30  |     |     |      |       |     |
| 31  |     |     |      |       |     |

<<Have minimums been met for this day?

County: Linn Agency: LINN COUNTY

**ENTRY POINT  
EP-A**

**PWS ID 4100474**

**LAWRENCE SUBDIVISION WTR ASSN**

Sample period: February / 2026  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.2

Print Name: Jody Anthony  
Signature: [Signature]  
Date & Phone#: 3-10-26 (541)990-9835

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0