



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.4				Y
2	7.1				Y
3	7.66				Y
4	8.10				Y
5	7.11				Y
6	7.36				Y
7	7.17				Y
8	7.1				Y
9	7.51				Y
10	8.39				Y
11	7.23				Y
12	7.15				Y
13	7.18				Y
14	8.16				Y
15	7.95				Y
16	7.67				Y
17	7.23				Y
18	7.17				Y
19	7.11				Y
20	7.46				Y
21	7.13				Y
22	7.12				X
23	7.20				Y
24	7.61				Y
25	7.12				Y
26	7.16				Y
27	7.18				Y
28	7.26				Y
29	7.67				Y
30	7.65				Y
31					

(No = N = Excursion) Total N's **0**

<<Have
minimums
been met for
this day?

County: Linn

Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100493

LYONS MEHAMA WATER DISTRICT

Sample period: September 2022
Month/Year.

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH **7.1**

Print Name: William A GRIMES

Signature: William A Grimes

Date: 10-3-22

Send to DWP within 10 days after end of
sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (503) 731-4381 Website: www.dhs.state.or.us/publichealth/dwp/index.cfm

11873 - 3352-1102