

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.55				Y
2	7.46				Y
3	7.38				Y
4	7.51				Y
5	7.45				Y
6	7.43				Y
7	7.34				Y
8	7.62				Y
9	7.44				Y
10	7.58				Y
11	7.38				Y
12	7.39				Y
13	7.42				Y
14	7.41				Y
15	7.44				Y
16	7.43				Y
17	7.32				Y
18	7.38				Y
19	7.27				Y
20	7.56				Y
21	7.67				Y
22	7.58				Y
23	7.39				Y
24	7.40				Y
25	7.46				Y
26	7.32				Y
27	7.56				Y
28	7.85				Y
29	7.62				Y
30	7.69				Y
31	7.48				Y

<<Have
minimums
been met for
this day?

County: Linn

Agency: REGION 1

ENTRY POINT

~~(EP-A)~~

PWS ID 4100493

LYONS MEHAMA WATER DISTRICT

Sample period: December 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: William A GRIMES

Signature: William A Grimes

Date: 12-31-22

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of
sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (503) 731-4381 Website: www.dhs.state.or.us/publichealth/dwp/index.cfm