

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.38				Y
2	7.47				Y
3	7.49				Y
4	7.24				Y
5	7.55				Y
6	7.53				Y
7	7.68				Y
8	7.63				Y
9	7.6				Y
10	7.58				Y
11	7.56				Y
12	7.64				Y
13	7.72				Y
14	7.38				Y
15	7.66				Y
16	7.11				Y
17	7.1				Y
18	7.63				Y
19	7.64				Y
20	7.71				Y
21	7.74				Y
22	7.87				Y
23	7.68				Y
24	7.66				Y
25	7.61				Y
26	7.65				Y
27	7.62				Y
28	7.45				Y
29	7.63				Y
30	7.85				Y
31	7.65				Y

<<Have
minimums
been met for
this day?

County: Linn

Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100493

LYONS MEHAMA WATER DISTRICT

Sample period: January 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: John Markert

Signature: John Markert

Date: 2-3-23

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (503) 731-4381 Website: www.dhs.state.or.us/publichealth/dwp/index.cfm