




# Lead & Copper Rule Corrosion Control

| Day | pH   | Alk | Phos | Sili | Y/N |
|-----|------|-----|------|------|-----|
| 1   | 7.25 |     |      |      | Y   |
| 2   | 7.18 |     |      |      | Y   |
| 3   | 7.24 |     |      |      | Y   |
| 4   | 7.38 |     |      |      | Y   |
| 5   | 7.18 |     |      |      | Y   |
| 6   | 7.19 |     |      |      | Y   |
| 7   | 7.1  |     |      |      | Y   |
| 8   | 7.41 |     |      |      | Y   |
| 9   | 7.41 |     |      |      | Y   |
| 10  | 7.45 |     |      |      | X   |
| 11  | 7.39 |     |      |      | Y   |
| 12  | 7.24 |     |      |      | Y   |
| 13  | 7.15 |     |      |      | Y   |
| 14  | 7.31 |     |      |      | Y   |
| 15  | 7.40 |     |      |      | Y   |
| 16  | 7.38 |     |      |      | X   |
| 17  | 7.30 |     |      |      | Y   |
| 18  | 7.13 |     |      |      | Y   |
| 19  | 7.25 |     |      |      | Y   |
| 20  | 7.33 |     |      |      | Y   |
| 21  | 7.42 |     |      |      | Y   |
| 22  | 7.22 |     |      |      | Y   |
| 23  | 7.24 |     |      |      | X   |
| 24  | 7.37 |     |      |      | X   |
| 25  | 7.24 |     |      |      | Y   |
| 26  | 7.62 |     |      |      | Y   |
| 27  | 7.44 |     |      |      | Y   |
| 28  | 7.29 |     |      |      | Y   |
| 29  | 7.27 |     |      |      | Y   |
| 30  | 7.47 |     |      |      | Y   |
| 31  | 7.55 |     |      |      | Y   |

<<Have minimums been met for this day?

County: Linn Agency: REGION 1

## ENTRY POINT



**PWS ID 4100493**

**LYONS MEHAMA WATER DISTRICT**

Sample period: December 2023  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

Print Name: John F Markert

Signature: *John F Markert*

Date: Jan 1st 2024

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period