



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.24				Y
2	7.42				Y
3	7.40				Y
4	7.59				Y
5	7.25				Y
6	7.13				Y
7	7.46				Y
8	7.01				Y
9	7.37				Y
10	7.42				Y
11	7.40				Y
12	7.13				Y
13	7.43				Y
14	7.46				Y
15	7.12				Y
16	7.65				Y
17	7.37				Y
18	7.28				Y
19	7.37				Y
20	7.54				Y
21	7.34				Y
22	7.51				Y
23	7.55				Y
24	7.49				Y
25	7.35				Y
26	7.01				Y
27	7.56				Y
28	8.46				Y
29	7.24				Y
30	7.13				Y
31	7.21				Y

<<Have minimums been met for this day?

County: Linn Agency: REGION 1

ENTRY POINT



PWS ID 4100493

LYONS MEHAMA WATER DISTRICT

Sample period: March 2024
Month/Year

Number of excursions during this month: 0
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.1

(No = N = Excursion) **Total N's** 0

Print Name: John Markert
 Signature: John F Markert
 Date: 4-3-2024

Send to DWP within 10 days after end of sampling period