



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.14				Y
2	7.34				Y
3	7.15				Y
4	7.88				Y
5	7.67				Y
6	7.57				Y
7	7.42				Y
8	7.36				Y
9	7.39				Y
10	7.50				Y
11	7.44				Y
12	7.40				Y
13	7.32				Y
14	7.31				Y
15	7.49				Y
16	7.20				Y
17	7.13				Y
18	7.17				Y
19	7.28				Y
20	7.38				Y
21	7.46				Y
22	7.38				Y
23	7.46				Y
24	7.12				Y
25	7.14				Y
26	7.39				Y
27	7.98				Y
28	7.23				Y
29	7.50				Y
30	7.52				Y
31	7.50				Y

<<Have minimums been met for this day?

County: Linn Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100493

LYONS MEHAMA WATER DISTRICT

Sample period: Aug 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.1

Print Name: John Markert

Signature: *John F. Markert*

Date: Aug 31ST 2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (503) 731-4381 Website: www.dhs.state.or.us/publichealth/dwp/index.cfm