



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.60				Y
2	7.62				Y
3	7.65				Y
4	7.67				Y
5	8.20				Y
6	8.12				Y
7	7.47				Y
8	7.55				Y
9	7.55				Y
10	8.24				Y
11	7.48				Y
12	7.93				Y
13	7.30				Y
14	7.41				Y
15	7.19				Y
16	7.52				Y
17	7.43				Y
18	7.39				Y
19	7.53				Y
20	7.41				Y
21	7.44				Y
22	7.44				Y
23	8.03				Y
24	8.39				Y
25	7.88				Y
26	7.12				Y
27	7.17				Y
28	7.1				Y
29	7.33				Y
30	7.40				Y
31					

<<Have minimums been met for this day?

County: Linn Agency: REGION 1

ENTRY POINT



PWS ID 4100493

LYONS MEHAMA WATER DISTRICT

Sample period: September 2024
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: John Marker IV

Signature: John F Marker IV

Date: September 1st 2024

(No = N = Excursion) **Total N's** 0

Send to DWP within 10 days after end of sampling period