

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control



Day	pH	Alk	Phos	Sili	Y/N
1	7.42				Y
2	7.35				Y
3	7.74				Y
4	7.33				Y
5	7.10				Y
6	7.17				Y
7	7.30				Y
8	7.33				Y
9	7.20				Y
10	7.30				Y
11	7.33				Y
12	7.36				Y
13	7.20				Y
14	7.26				Y
15	7.34				Y
16	7.38				Y
17	7.39				Y
18	7.25				Y
19	7.29				Y
20	7.12				Y
21	7.40				Y
22	7.25				Y
23	7.34				Y
24	7.13				Y
25	7.10				Y
26	7.24				Y
27	7.18				Y
28	8.35				Y
29	7.20				Y
30	7.25				Y
31					

<<Have
minimums
been met for
this day?

County: Linn

Agency: REGION 1

ENTRY POINT



PWS ID 4100493

LYONS MEHAMA WATER DISTRICT

Sample period: November 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: John Markert

Signature: John F Markert II

Date: Dec 1st 2024

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (503) 731-4381 Website: www.dhs.state.or.us/publichealth/dwp/index.cfm