

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.43				Y
2	7.71				Y
3	7.47				Y
4	7.56				Y
5	7.37				Y
6	7.26				Y
7	7.54				Y
8	7.49				Y
9	7.85				Y
10	8.58				Y
11	7.57				Y
12	7.33				Y
13	7.01				Y
14	7.36				Y
15	7.33				Y
16	7.14				Y
17	7.62				Y
18	7.38				Y
19	7.30				Y
20	7.45				Y
21	7.60				Y
22	7.29				Y
23	7.48				Y
24	7.36				Y
25	7.57				Y
26	7.68				Y
27	7.60				Y
28	7.43				Y
29	7.40				Y
30	7.50				Y
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	4	9	3
---	---	---	---	---

System Name: Lyons mehana Water District

Entry Point: _____

Sample Period: June 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH		
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: John Markert

Signature: [Signature]

Date: 6-30-2025

Send to DWP within 10 days after end of
sampling period

0 = N = Excursion) Total N's 0