

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.42				Y
2	7.25				Y
3	7.44				Y
4	7.38				Y
5	7.51				Y
6	7.42				Y
7	7.50				Y
8	7.34				Y
9	7.38				Y
10	7.39				Y
11	7.33				Y
12	7.43				Y
13	7.25				Y
14	7.28				Y
15	7.42				Y
16	7.19				Y
17	7.20				Y
18	7.81				Y
19	7.30				Y
20	7.46				Y
21	7.25				Y
22	7.25				Y
23	7.28				Y
24	7.19				Y
25	8.40				Y
26	7.21				Y
27	7.18				Y
28	8.14				Y
29	7.76				Y
30	7.66				Y
31	7.62				Y
No = N = Excursion) Total N's					0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

00493

System Name: lyons mehana water district

Entry Point: _____

Sample Period: July 2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other (_____)

Print Name: John Markert

Signature: John Markert

Date: 8-5-2025

Send to DWP within 10 days after end of sampling period