

Day	pH	Alk	Phos	Other	Y/N
1	7.37				Y
2	7.48				Y
3	7.84				Y
4	7.45				Y
5	7.10				Y
6	7.58				Y
7	8.67				Y
8	7.93				Y
9	7.89				Y
10	7.57				Y
11	7.71				Y
12	7.63				Y
13	7.70				Y
14	7.85				Y
15	7.38				Y
16	7.81				Y
17	7.17				Y
18	7.65				Y
19	7.85				Y
20	7.72				Y
21	7.96				Y
22	7.61				Y
23	7.20				Y
24	7.79				Y
25	7.71				Y
26	7.85				Y
27	7.81				Y
28	7.33				Y
29					
30					
31					

= N = Excursion) Total N's 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 08493

System Name: Lyons Mahama Water

Entry Point: _____

Sample Period: February 2026
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: John Marker J

Signature: [Signature]

Date: March 2 2026

Send to DWP within 10 days after end of sampling period