



# Water Quality Parameter Monitoring Form


## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.33				Y
2	7.57				Y
3	7.29				Y
4	7.45				Y
5	7.32				Y
6	7.69				Y
7	7.59				Y
8	7.30				Y
9	7.28				Y
10	7.51				Y
11	7.51				Y
12	7.11				Y
13	7.34				Y
14	7.58				Y
15	7.47				Y
16	7.23				Y
17	7.61				Y
18	7.15				Y
19	7.32				Y
20	7.47				Y
21	7.15				Y
22	7.12				Y
23	7.40				Y
24	7.33				Y
25	7.32				Y
26	7.44				Y
27	7.34				Y
28	7.40				Y
29	7.46				Y
30	7.28				Y
31	7.16				Y

<<Have minimums been met for this day?

County: Linn Agency: REGION 1

### ENTRY POINT



**PWS ID 4100493**

**LYONS MEHAMA WATER DISTRICT**

Sample period: JAN 2021  
Month/Year

Number of excursions during this month: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

Print Name: William A Grimes  
Signature: William A Grimes  
Date: 1 Feb 2021

No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period