



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.67				Y
2	7.23				Y
3	7.20				Y
4	7.31				Y
5	7.51				Y
6	7.58				Y
7	7.49				Y
8	7.54				Y
9	7.58				Y
10	7.37				Y
11	7.17				Y
12	7.72				Y
13	7.37				Y
14	7.51				Y
15	7.42				Y
16	7.53				Y
17	7.62				Y
18	7.59				Y
19	7.55				Y
20	7.53				Y
21	7.41				Y
22	7.54				Y
23	7.72				Y
24	7.65				Y
25	7.69				Y
26	7.54				Y
27	7.64				Y
28	7.74				Y
29	7.73				Y
30	7.64				Y
31					

<<Have minimums been met for this day?

County: Linn Agency: REGION 1

**ENTRY POINT**

~~EP-A~~

**PWS ID 4100493**

**LYONS MEHAMA WATER DISTRICT**

Sample period: April 2021  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

Print Name: William A GRIMES

Signature: William A Grimes

Date: 6 May 2021

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 0