



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.38				Y
2	7.37				Y
3	7.25				Y
4	7.40				Y
5	7.61				Y
6	7.64				Y
7	7.27				Y
8	7.45				Y
9	7.54				Y
10	7.22				Y
11	7.32				Y
12	7.40				Y
13	7.59				Y
14	7.28				Y
15	7.12				Y
16	7.61				Y
17	7.54				Y
18	7.24				Y
19	7.27				Y
20	7.34				Y
21	7.33				Y
22	7.20				Y
23	7.33				Y
24	7.21				Y
25	7.13				Y
26	7.14				Y
27	7.62				Y
28	7.49				Y
29	7.64				Y
30	7.28				Y
31					

<<Have minimums been met for this day?

County: Linn Agency: REGION 1

ENTRY POINT



PWS ID 4100493

LYONS MEHAMA WATER DISTRICT

Sample period: June 2021
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

Minimum Water Quality Parameter(s) as set by State:

pH 7.1

Print Name: William A GRIMES

Signature: William A Grimes

Date: 1 July 2021

Send to DWP within 10 days after end of sampling period

0 = N = Excursion) Total N's