



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.1				Y
2	7.16				Y
3	8.25				Y
4	7.49				Y
5	8.20				Y
6	8.17				Y
7	7.49				Y
8	7.30				Y
9	7.34				Y
10	7.73				Y
11	7.46				Y
12	7.58				Y
13	7.47				Y
14	7.38				Y
15	7.43				Y
16	7.19				Y
17	7.7				Y
18	7.4				Y
19	7.68				Y
20	7.8				Y
21	7.38				Y
22	7.43				Y
23	7.47				Y
24	7.5				Y
25	7.7				Y
26	7.48				Y
27	7.42				Y
28	7.12				Y
29	7.58				Y
30	7.72				Y
31	7.89				Y

<<Have minimums been met for this day?

County: Linn Agency: REGION 1

ENTRY POINT



PWS ID 4100493

LYONS MEHAMA WATER DISTRICT

Sample period: AUG 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: William A GRIMES

Signature: William A Grimes

Date: 8-1-21

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period