

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**



Day	pH	Alk	Phos	Sili	Y/N
1	7.4				Y
2	7.11				Y
3	7.92				Y
4	7.47				Y
5	7.33				Y
6	7.36				Y
7	7.83				Y
8	7.86				Y
9	7.78				Y
10	8.06				Y
11	7.39				Y
12	7.40				Y
13	7.9				Y
14	7.48				Y
15	7.78				Y
16	8.24				Y
17	7.56				Y
18	7.15				Y
19	7.17				Y
20	7.90				Y
21	8.03				Y
22	7.36				Y
23	8.01				Y
24	7.84				Y
25	7.45				Y
26	7.30				Y
27	7.52				Y
28	7.87				Y
29	7.53				Y
30	8.67				Y
31					

<<Have minimums been met for this day?

County: Linn Agency: REGION 1

**ENTRY POINT**



**PWS ID 4100493**

**LYONS MEHAMA WATER DISTRICT**

Sample period: Sep 2021  
 Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

Print Name: William A GRIMES

Signature: William A Grimes

Date: 2 Oct 2021

Send to DWP within 10 days after end of sampling period

% = N = Excursion) **Total N's** 0