



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.54				Y
2	7.70				Y
3	7.42				Y
4	7.46				Y
5	7.60				Y
6	7.60				Y
7	7.66				Y
8	7.23				Y
9	7.46				Y
10	7.5				Y
11	7.1				Y
12	7.65				Y
13	7.49				Y
14	7.73				Y
15	7.6				Y
16	7.71				Y
17	7.13				Y
18	7.24				Y
19	7.25				Y
20	7.72				Y
21	7.85				Y
22	7.49				Y
23	7.15				Y
24	7.18				Y
25	7.87				Y
26	7.12				Y
27	7.28				Y
28	7.18				Y
29	7.15				Y
30	7.11				Y
31					

<<Have minimums been met for this day?

County: Linn Agency: REGION 1

### ENTRY POINT



**PWS ID 4100493**

**LYONS MEHAMA WATER DISTRICT**

Sample period: NOV 2021  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

Print Name: William A GEIMES

Signature: William A Geimes

Date: 12-1-21

Send to DWP within 10 days after end of sampling period

No = N = Excursion) **Total N's** 0