



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.52				Y
2	7.36				Y
3	7.38				Y
4	7.13				Y
5	7.61				Y
6	7.23				Y
7	7.21				Y
8	7.31				Y
9	7.30				Y
10	7.18				Y
11	7.76				Y
12	8.35				Y
13	7.28				Y
14	7.81				Y
15	7.33				Y
16	7.51				Y
17	7.52				Y
18	7.45				Y
19	7.52				Y
20	7.50				Y
21	7.37				Y
22	7.59				Y
23	7.47				Y
24	7.72				Y
25	7.62				Y
26	7.25				Y
27	7.14				Y
28	7.57				Y
29					
30					
31					

<<Have minimums been met for this day?

County: Linn Agency: REGION 1

### ENTRY POINT



**PWS ID 4100493**

**LYONS MEHAMA WATER DISTRICT**

Sample period: February 2022  
Month/Year

Number of excursions during this month: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

Print Name: William A GRIMES  
Signature: William A Grimes  
Date: 3-3-22

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 0