



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.53				Y
2	7.38				Y
3	7.53				Y
4	7.33				Y
5	7.77				Y
6	7.14				Y
7	7.5				Y
8	7.44				Y
9	7.35				Y
10	7.51				Y
11	7.58				Y
12	7.88				Y
13	7.68				Y
14	7.68				Y
15	7.78				Y
16	7.74				Y
17	7.51				Y
18	7.56				Y
19	7.27				Y
20	7.61				Y
21	7.54				Y
22	7.43				Y
23	7.54				Y
24	7.39				Y
25	7.30				Y
26	7.46				Y
27	7.67				Y
28	7.43				Y
29	7.47				Y
30	7.62				Y
31	7.52				Y

<<Have minimums been met for this day?

County: Linn Agency: REGION 1

ENTRY POINT



PWS ID 4100493

LYONS MEHAMA WATER DISTRICT

Sample period: MAR 2022
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.1

Print Name: William A GRIMES
 Signature: William A Grimes
 Date: 3-31-22

(No = N = Excursion) **Total N's** 0

Send to DWP within 10 days after end of sampling period