



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.63				Y
2	7.59				Y
3	7.55				Y
4	7.43				Y
5	7.59				Y
6	8.02				Y
7	7.22				Y
8	7.12				Y
9	7.46				Y
10	8.4				Y
11	7.70				Y
12	7.72				Y
13	7.91				Y
14	7.38				Y
15	7.33				Y
6	7.5				Y
17	7.27				Y
18	7.11				Y
19	7.11				Y
20	7.29				Y
21	7.27				Y
22	7.54				Y
23	7.44				Y
24	7.67				Y
25	7.46				Y
26	7.69				Y
27	7.24				Y
28	7.31				Y
29	7.53				Y
30	7.38				Y
31					

<<Have minimums been met for this day?

County: Linn Agency: REGION 1

## ENTRY POINT



**PWS ID 4100493**

**LYONS MEHAMA WATER DISTRICT**

Sample period: June 2022  
Month/Year

Number of excursions during this month: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.1

Print Name: William A GRIMES  
Signature: William A Grimes  
Date: 4 July 2022

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period