

City of Manzanita

OHA / DWP

Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?
1	7.30				Y	
2	7.23				Y	
3	7.26				Y	
4	7.38				Y	
5	7.26				Y	
6	7.38				Y	
7	7.26				Y	
8	7.26				Y	
9	7.27				Y	
10	7.23				Y	
11	7.41				Y	
12	7.36				Y	
13	7.38				Y	
14	7.42				Y	
15	7.23				Y	
16	7.38				Y	
17	7.35				Y	
18	7.41				Y	
19	7.35				Y	
20	7.23				Y	
21	7.21				Y	
22	7.25				Y	
23	7.28				Y	
24	7.31				Y	
25	7.28				Y	
26	7.24				Y	
27	7.21				Y	
28	7.27				Y	
29	7.32				Y	
30	7.35				Y	
31	7.36				Y	

County: Tillamook Agency: Region 1

**ENTRY POINT**  
**EP-C**  
**PWS ID: 4 | 1 | 0 | 0 | 5 | 0 | 5**

**SYSTEM NAME:** City of Manzanita

**SAMPLE PERIOD:** July-22  
MONTH / YEAR

**Number of excursions\* during this month:** 0

**(Over 9 excursions in 6 months is a violation.)**  
Entry Point and Distribution excursions are cumulative)

*\* An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameters set for this PWS:**

pH 7.2

**Print Name:** Daniel L. Weitzel

**Signature:** *Daniel L. Weitzel*

**Cert. #:** WD1- #7191 / WT2 - # 08183

**Date:** Wednesday, August 3, 2022

**Phone:** (503) 368-5347

(No = N = Excursion) Total N's 0

**Send to DHS-DWP within 10 days after end of sampling period to:**  
**DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350**  
**Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp**