

City of Manzanita

OHA / DWP

Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.41				Y
2	7.43				Y
3	7.33				Y
4	7.33				Y
5	7.31				Y
6	7.32				Y
7	7.31				Y
8	7.30				Y
9	7.37				Y
10	7.35				Y
11	7.29				Y
12	7.36				Y
13	7.31				Y
14	7.34				Y
15	7.34				Y
16	7.36				Y
17	7.36				Y
18	7.29				Y
19	7.32				Y
20	7.28				Y
21	7.29				Y
22	7.43				Y
23	7.28				Y
24	7.30				Y
25	7.30				Y
26	7.30				Y
27	7.32				Y
28	7.33				Y
29	7.39				Y
30	7.38				Y
31	7.33				Y

(No = N = Excursion) Total N's **0**

County: Tillamook Agency: Region 1

ENTRY POINT
EP-C
PWS ID: 4 | 1 | 0 | 0 | 5 | 0 | 5



SYSTEM NAME: City of Manzanita

SAMPLE PERIOD: August-22
 MONTH / YEAR

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation.)
 Entry Point and Distribution excursions are cumulative)

* An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameters set for this PWS:

pH

Print Name: Daniel L. Weitzel
Signature: *Daniel L Weitzel*
Cert. #: WD1- #7191 / WT2 - # 08183
Date: Thursday, September 22, 2022
Phone: (503) 368-5347

Send to DHS-DWP within 10 days after end of sampling period to:
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp