

OHA / DWP

Oregon Health Authority


**Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

Day	pH	Alk	Phos	Sili	Y/N
1	7.73				Y
2	7.42				Y
3	7.39				Y
4	7.41				Y
5	7.27				Y
6	7.56				Y
7	7.34				Y
8	7.33				Y
9	7.30				Y
10	7.55				Y
11	7.42				Y
12	7.28				Y
13	7.37				Y
14	7.33				Y
15	7.26				Y
16	7.86				Y
17	7.85				Y
18	7.46				Y
19	7.38				Y
20	7.38				Y
21	7.30				Y
22	7.38				Y
23	7.27				Y
24	7.32				Y
25	7.30				Y
26	7.37				Y
27	7.32				Y
28	7.40				Y
1	0.00				-
2	0.00				-
3	0.00				-

<< Have minimums been met for this day?

ENTRY POINT
EP-C 
PWS ID: 4 | 1 | 0 | 0 | 5 | 0 | 5

SYSTEM NAME: City of Manzanita

SAMPLE PERIOD: February-23
 MONTH / YEAR

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation.)
Entry Point and Distribution excursions are cumulative)

** An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

Minimum Water Quality Parameters set for this PWS:

pH

Print Name: Daniel L. Weitzel
Signature: *Daniel L. Weitzel*
Cert. #: WD2- #7191 / WT2 - # 08183
Date: Wednesday, March 1, 2023
Phone: (503) 368-5347

(No = N = Excursion) Total N's **0**

Send to DHS-DWP within 10 days after end of sampling period to:
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp