

# OHA / DWP

Oregon Health Authority

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	pH	Alk	Phos	Sili	Y/N
1	7.37				Y
2	7.40				Y
3	7.37				Y
4	7.38				Y
5	7.37				Y
6	7.39				Y
7	7.36				Y
8	7.23				Y
9	7.34				Y
10	7.38				Y
11	7.35				Y
12	7.37				Y
13	7.38				Y
14	7.36				Y
15	7.36				Y
16	7.34				Y
17	7.30				Y
18	7.29				Y
19	7.37				Y
20	7.41				Y
21	7.38				Y
22	7.35				Y
23	7.33				Y
24	7.41				Y
25	7.27				Y
26	7.41				Y
27	7.39				Y
28	7.40				Y
29	7.38				Y
30	7.39				Y
31	7.39				Y

<< Have minimums been met for this day?

**ENTRY POINT**

**EP-C**

**PWS ID: 4 | 1 | 0 | 0 | 5 | 0 | 5**

**SYSTEM NAME:**

City of Manzanita

**SAMPLE PERIOD:**

July-23

MONTH / YEAR

**Number of excursions\* during this month:**

0

**(Over 9 excursions in 6 months is a violation.)**

*Entry Point and Distribution excursions are cumulative)*

*\* An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality**

**Parameters set for this PWS:**

pH

**Print Name:**

Daniel L. Weitzel

**Signature:**

*Daniel L. Weitzel*

**Cert. #:**

WD2- #7191 / WT2 - # 08183

**Date:**

Tuesday, August 8, 2023

**Phone:**

(503) 368-5347

(No = N = Excursion)

Total N's

**0**

**Send to DHS-DWP within 10 days after end of sampling period to:  
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp**