

OHA / DWP

Oregon Health Authority

**Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

Day	pH	Alk	Phos	Sili	Y/N
1	7.29				Y
2	7.21				Y
3	7.25				Y
4	7.37				Y
5	7.36				Y
6	7.31				Y
7	7.33				Y
8	7.36				Y
9	7.37				Y
10	7.49				Y
11	7.42				Y
12	7.37				Y
13	7.42				Y
14	7.38				Y
15	7.41				Y
16	7.40				Y
17	7.39				Y
18	7.38				Y
19	7.32				Y
20	7.37				Y
21	7.39				Y
22	7.50				Y
23	7.41				Y
24	7.34				Y
25	7.42				Y
26	7.42				Y
27	7.51				Y
28	7.39				Y
29	7.38				Y
30	7.29				Y
31	7.28				Y

<< Have minimums been met for this day?

ENTRY POINT
EP-C
PWS ID: 4 | 1 | 0 | 0 | 5 | 0 | 5

SYSTEM NAME: City of Manzanita

SAMPLE PERIOD: August-24
MONTH / YEAR

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation.)
Entry Point and Distribution excursions are cumulative)

* An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameters set for this PWS:

pH

Print Name: Daniel L. Weitzel

Signature: *Daniel L. Weitzel*

Cert. #: WD2- #7191 / WT2 - # 08183

Date: Sunday, September 8, 2024

Phone: (503) 368-5347

(No = N = Excursion) Total N's **0**

Send to DHS-DWP within 10 days after end of sampling period to:
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp