

# OHA / DWP

Oregon Health Authority

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	pH	Alk	Phos	Sili	Y/N	
1	7.6				Y	
2	7.5				Y	
3	7.5				Y	
4	7.9				Y	
5	7.4				Y	
6	7.4				Y	
7	7.4				Y	
8	7.5				Y	
9	7.5				Y	
10	7.5				Y	
11	7.5				Y	
12	7.5				Y	
13	7.6				Y	
14	7.5				Y	
15	7.4				Y	
16	7.5				Y	
17	7.6				Y	
18	7.5				Y	
19	7.5				Y	
20	7.6				Y	
21	7.6				Y	
22	7.6				Y	
23	7.6				Y	
24	7.5				Y	
25	7.6				Y	
26	7.4				Y	
27	7.5				Y	
28	7.6				Y	
29	7.5				Y	
30	7.5				Y	
(No = N = Excursion)					Total N's	<b>0</b>

<< Have minimums been met for this day?

**ENTRY POINT**

**EP-C**

**PWS ID: 4 | 1 | 0 | 0 | 5 | 0 | 5**

**SYSTEM NAME:**

**City of Manzanita**

**SAMPLE PERIOD:**

**November-24**

**MONTH / YEAR**

**Number of excursions\* during this month:**

**0**

**(Over 9 excursions in 6 months is a violation.)**

*Entry Point and Distribution excursions are cumulative)*

*\* An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality**

**Parameters set for this PWS:**

pH **7.2**

**Print Name:**

Daniel L. Weitzel

**Signature:**

*Daniel L. Weitzel*

**Cert. #:**

WD2- #7191 / WT2 - # 08183

**Date:**

Monday, December 2, 2024

**Phone:**

(503) 368-5347

**Send to DHS-DWP within 10 days after end of sampling period to:  
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp**