

OHA / DWP

Oregon Health Authority

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	pH	Alk	Phos	Sili	Y/N
1	7.5				Y
2	7.5				Y
3	7.5				Y
4	7.5				Y
5	7.6				Y
6	7.6				Y
7	7.6				Y
8	7.6				Y
9	7.5				Y
10	7.5				Y
11	7.6				Y
12	7.6				Y
13	7.6				Y
14	7.6				Y
15	7.5				Y
16	7.6				Y
17	7.6				Y
18	7.5				Y
19	7.6				Y
20	7.6				Y
21	7.5				Y
22	7.5				Y
23	7.5				Y
24	7.6				Y
25	7.5				Y
26	7.5				Y
27	7.2				Y
28	7.2				Y
29	7.2				Y
30	7.3				Y
	7.2				Y

<< Have minimums been met for this day?

ENTRY POINT

EP-C



PWS ID: 4 | 1 | 0 | 0 | 5 | 0 | 5

SYSTEM NAME:

City of Manzanita

SAMPLE PERIOD:

December-24

MONTH / YEAR

Number of excursions* during this month:

0

(Over 9 excursions in 6 months is a violation.)

Entry Point and Distribution excursions are cumulative)

** An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

Minimum Water Quality

Parameters set for this PWS:

pH **7.2**

Print Name:

Daniel L. Weitzel

Signature:

Daniel L. Weitzel

Cert. #:

WD2- #7191 / WT2 - # 08183

Date:

Monday, January 6, 2025

Phone:

(503) 368-5347

(No = N = Excursion)

Total N's

0

**Send to DHS-DWP within 10 days after end of sampling period to:
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp**