

OHA / DWP

Oregon Health Authority

**Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

| Day | pH | Alk | Phos | Sili | Y/N |
|-----|-----|-----|------|------|-----|
| 1 | 7.5 | | | | Y |
| 2 | 7.4 | | | | Y |
| 3 | 7.4 | | | | Y |
| 4 | 7.4 | | | | Y |
| 5 | 7.4 | | | | Y |
| 6 | 7.4 | | | | Y |
| 7 | 7.3 | | | | Y |
| 8 | 7.5 | | | | Y |
| 9 | 7.4 | | | | Y |
| 10 | 7.4 | | | | Y |
| 11 | 7.4 | | | | Y |
| 12 | 7.4 | | | | Y |
| 13 | 7.3 | | | | Y |
| 14 | 7.3 | | | | Y |
| 15 | 7.4 | | | | Y |
| 16 | 7.4 | | | | Y |
| 17 | 7.3 | | | | Y |
| 18 | 7.3 | | | | Y |
| 19 | 7.3 | | | | Y |
| 20 | 7.3 | | | | Y |
| 21 | 7.3 | | | | Y |
| 22 | 7.3 | | | | Y |
| 23 | 7.3 | | | | Y |
| 24 | 7.3 | | | | Y |
| 25 | 7.3 | | | | Y |
| 26 | 7.3 | | | | Y |
| 27 | 7.3 | | | | Y |
| 28 | 7.4 | | | | Y |
| 29 | 7.4 | | | | Y |
| 30 | 7.4 | | | | Y |
| 31 | 7.5 | | | | Y |

<< Have minimums been met for this day?

ENTRY POINT

EP-C

PWS ID: 4 | 1 | 0 | 0 | 5 | 0 | 5

SYSTEM NAME:

City of Manzanita

SAMPLE PERIOD:

January-25

MONTH / YEAR

Number of excursions* during this month:

0

(Over 9 excursions in 6 months is a violation.)

Entry Point and Distribution excursions are cumulative)

** An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality
Parameters set for this PWS:**

pH **7.2**

(No = N = Excursion)

Total N's

0

Print Name:

Daniel L. Weitzel

Signature:

Daniel L. Weitzel

Cert. #:

WD2- #7191 / WT2 - # 08183

Date:

Wednesday, February 5, 2025

Phone:

(503) 368-5347

**Send to DHS-DWP within 10 days after end of sampling period to:
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp**