OHA / DWP

Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrision Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP-B

PWS ID: 4 | 1 | 0 | 0 | 5 | 0 | 5

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?
1	7.6				Y	
2	7.6				Y	
3	7.6				Y	
4	7.5				Y	
5	7.5				Y	
6	7.5				Y	
7	7.5				Y	
8	7.5				Y	
9	7.5				Y	
10	7.5				Y	
11	7.6				Y	
12	7.5				Y	
13	7.6				Y	
14	7.6				Y	
15	7.6				Y	
16	7.6				Y	
17	7.6				Y	
18	7.6				Y	
19	7.5				Y	
20	7.6				Y	
21	7.6				Y	
22	7.6				Y	
23	7.6				Y	
24	7.6				Y	
25	7.6				Y	
26	7.6				Y	
27	7.6				Y	
28	7.6				Y	
(No = N =	0		Total N's		**0**	

SYSTEM NAME: **City of Manzanita**

SAMPLE PERIOD: **February-2026**

MONTH / YEAR

Number of excursions* during this month: **0**

(Over 9 excursions in 6 months is a violation.)

Entry Point and Distribution excursions are cumulative)

** An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

Minimum Water Quality Parameters set for this PWS:

pH **7.2**

Print Name: Rick Rempfer

Signature: *Rick Rempfer*

Cert. #: D1-144265 / T1-144265

Date: Wednesday, March 4, 2026

Phone: (503) 368-5347

Send to DHS-DWP within 10 days after end of sampling period to:
DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp

graph: &R 3/4/2026, 8:09 AMs