

Day	pH	Alk	Phos	Other	Y/N
1					
2	8.03	56.0			Y
3					
4					
5					
6					
7					
8	7.70	52.0			Y
9					
10					
11					
12					
13					
14					
15	7.65	54.4			Y
16					
17					
18					
19					
20					
21					
22	7.67	56.0			Y
23					
24					
25					
26					
27					
28					
29	7.57	58.4			Y
30					
31					

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100506**

**NEAHKAHNE WATER DISTRICT**

Sample period: March / 2021  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0
Alk	50.0 (Alkalinity)

Print Name: Scott A Merrill  
 Signature: [Signature]  
 Date & Phone#: 3.31.21 (503) 904-4649

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0