



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7	7.59	66.4			Y
8					
9					
10					
11					
12					
13					
14	7.41	65.8			Y
15					
16					
17					
18					
19					
20					
21	7.56	68.0	2.0		Y
22					
23					
24					
25					
26					
27					
28	7.45	66.4			Y
29					
30					
31					

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100506**

**NEAHKAHNE WATER DISTRICT**

Sample period: June / 2021  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 

7.0
-----

  
 Alk 

50.0
------

 (Alkalinity)

Print Name: Scott A. Merrill  
 Signature: Scott A. Merrill  
 Date & Phone#: 6.30.21 (503) 804.4649  
 Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0