

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.45	68.8			Y
5					
6					
7					
8					
9					
10					
11	7.45	67.4			Y
12					
13					
14					
15					
16					
17					
18	7.41	74.4			Y
19					
20					
21					
22					
23					
24					
25	7.32	71.2			Y
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100506**

**NEAHKAHNE WATER DISTRICT**

Sample period: Oct/2021  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0
Alk	50.0 (Alkalinity)

Print Name: Scott Merrill

Signature: Scott Merrill

Date & Phone#: 10.31.21 (503) 804-4649

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0