

Day	pH	Alk	Phos	Other	Y/N
1					
2	8.09	60.0			Y
3					
4					
5					
6					
7					
8					
9					
10	7.69	58.4			Y
11					
12					
13					
14					
15					
16	7.49	57.6			Y
17					
18					
19					
20					
21					
22					
23	7.50	55.2			Y
24					
25					
26					
27					
28					
29					
30	7.53	56.0			Y
31					

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

ENTRY POINT

EP-A

PWS ID 4100506

NEAHKAHNE WATER DISTRICT

Sample period: Jan/2023
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

2/2/23

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.0
 Alk 50.0 (Alkalinity)

Print Name: Scott A Marcell
 Signature: Scott A Marcell
 Date & Phone#: 1-31-23 (503) 804-4649

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0