

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7	7.71	68.8			Y
8					
9					
10					
11					
12					
13					
14	7.89	66.4			Y
15					
16					
17					
18					
19					
20					
21	7.98	67.2			Y
22					
23					
24					
25					
26					
27					
28	7.71	68.0			Y
29					
30					
31					

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100506**

**NEAHKAHNIE WATER DISTRICT**

Sample period: August / 2023  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.0  
 Alk 50.0 (Alkalinity)

Print Name: Scott A Morrill

Signature: [Signature]

Date & Phone#: 8.31.23 (503) 804-4649

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0